



UL/4X

G.P.T CO


PUMP CONTROL PANEL - ELECTRICAL DRAWINGS

SH	FILENAME
00	TITLE PAGE
01	DRAWING NOTES PAGE
10	230/460 VAC DISTRIBUTION
20	120 VAC CONTROL CIRCUIT
70	TERMINAL BLOCK LAYOUT
80	ENCLOSURE LAYOUT PAGE-1
81	ENCLOSURE LAYOUT PAGE-2

MODEL NUMBER: GPDL3-15/7.5
ITEM NUMBER: 3970252

						BRAND: G.P.T.CO	
						PROJECT DESC: PUMP CONTROL PANEL	
						DRAWING DESC: 00 - TITLE PAGE	
REV.	CHANGE	DATE	NAME	MODEL NUMBER:	GPD L3 15/7.5		
				ITEM NUMBER:	3970252		SHEET #: 00

CUSTOMER SUPPLIED
460V or 230V, 3PH, 60Hz
Note: Disconnect supplied in the field




FOR 230VAC MODELS
7.5 HP AT 230VAC, 22FLA

FOR 230VAC MODELS
7.5 HP AT 230VAC, 22FLA




TRANSFORMER CONNECTION		
Primary Volts	Voltage (VAC)	Install Supplied Links Between Terminals
	230	H1-H3,H2-H4
	460	H2-H3

10XF22
PRI: 460VAC OR 230VAC
SEC: 120VAC
250VA

						BRAND: G.P.T.CO	
						PROJECT DESC: PUMP CONTROL PANEL	
						DRAWING DESC: 10 - 230/460 VAC DISTRIBUTION	
REV.	CHANGE	DATE	NAME	MODEL NUMBER:	GPDL3 15/7.5		
				ITEM NUMBER:	3970252		
						SHEET #: 10	



							BRAND: G.P.T.CO	
							PROJECT DESC: PUMP CONTROL PANEL	
							DRAWING DESC: 20 - 120 VAC CONTROL CIRCUIT	
REV.	CHANGE	DATE	NAME	MODEL NUMBER:	GPDL3 15/7.5			
				ITEM NUMBER:	3970252			
							SHEET #: 20	



							BRAND: G.P.T.CO	
							PROJECT DESC: PUMP CONTROL PANEL	
				MODEL NUMBER:	GPDL3 15/7.5		DRAWING DESC: 80 - ENCLOSURE LAYOUT PAGE-1	
REV.	CHANGE	DATE	NAME	ITEM NUMBER:	3970252		SHEET # 80	

