




UL/4X

G.P.T CO


PUMP CONTROL PANEL - ELECTRICAL DRAWINGS

SH	FILENAME
00	TITLE PAGE
01	DRAWING NOTES PAGE
10	230/460 VAC DISTRIBUTION
20	120 VAC CONTROL CIRCUIT
70	TERMINAL BLOCK LAYOUT
80	ENCLOSURE LAYOUT PAGE-1
81	ENCLOSURE LAYOUT PAGE-2

MODEL NUMBER: GPDL3-20/10
ITEM NUMBER: 3970253

					BRAND: G.P.T.CO	
					PROJECT DESC: PUMP CONTROL PANEL	
					DRAWING DESC: 00 - TITLE PAGE	
REV.	CHANGE	DATE	NAME			SHEET #: 00

CUSTOMER SUPPLIED
460V or 230V, 3PH, 60Hz
Note: Disconnect supplied in the field




FOR 230VAC MODELS
10 HP AT 230VAC, 28FLA

FOR 230VAC MODELS
10 HP AT 230VAC, 28FLA

TRANSFORMER CONNECTION		
Primary Volts	Voltage (VAC)	Install Supplied Links Between Terminals
	230	H1-H3,H2-H4
	460	H2-H3




10XF22
PRI: 460VAC OR 230VAC
SEC: 120VAC
250VA

					BRAND: G.P.T.CO	
					PROJECT DESC: PUMP CONTROL PANEL	
					DRAWING DESC: 10 - 230/460 VAC DISTRIBUTION	
REV.	CHANGE	DATE	NAME	MODEL NUMBER:	GPD.L3 20/10	
				ITEM NUMBER:	3970253	
						SHEET #: 10



					BRAND: G.P.T.CO	
					PROJECT DESC: PUMP CONTROL PANEL	
					DRAWING DESC: 20 - 120 VAC CONTROL CIRCUIT	
REV.	CHANGE	DATE	NAME			SHEET # 20
				MODEL NUMBER:	GPD13 20/10	
				ITEM NUMBER:	3970253	



70 01
70 02
70 03
70 04
70 05
70 06
70 07
70 08
70 09
70 10
70 11
70 12
70 13
70 14
70 15
70 16
70 17
70 18
70 19
70 20
70 21
70 22
70 23
70 24
70 25
70 26
70 27
70 28
70 29
70 30
70 31
70 32
70 33
70 34
70 35
70 36




GPT
CO

							BRAND: G.P.T.CO	
							PROJECT DESC: PUMP CONTROL PANEL	
							DRAWING DESC: 70 - TERMINAL BLOCK LAYOUT	
REV.	CHANGE	DATE	NAME				SHEET #: 70	

MODEL NUMBER:	GPDL3 20/10	
ITEM NUMBER:	3970253	



							BRAND: G.P.T.CO	
							PROJECT DESC: PUMP CONTROL PANEL	
				DRAWING DESC: 80 - ENCLOSURE LAYOUT PAGE-1				
REV.	CHANGE	DATE	NAME	MODEL NUMBER:	GPD13 20/10			
				ITEM NUMBER:	3970253			

